



**TOWN OF WASHINGTON
BUILDING AND ZONING DEPARTMENT
P.O. Box 667, 10 Reservoir Drive
Millbrook, NY 12545
Phone (845) 677-3419 Fax (845) 677-1195
Email: buildinginspector@washingtonny.org
www.washingtonny.org Cell: (845) 219-9724**

6/3/2025

RE: 443 Valley Farm Road; 6766-00-289555

To whom it may concern;

This letter is in regards to Condition B of a resolution by the Town of Washington Planning Board in regards to a Wetlands Permit Application. Condition B for approval requires confirmation by the Town of Washington Building Department that no improvements to the existing septic system will be required as no new bedrooms will be added. This is confirmed as the only time a septic system needs to be reviewed, replaced or increased is when any improvement to the structure will add additional bedrooms. Since no new bedrooms are to be added, no work will have to be done to the existing septic system. Please feel free to contact the Town of Washington Building Department with any further questions or concerns.

Sincerely;

Jonathan Iatongo
Building Inspector and Zoning Administrator